

# ERRATA

## To American Iron and Steel Institute (AISI) *Standard for Cold-Formed Steel Framing - Prescriptive Method for One and Two Family Dwellings with Supplement 2 (S230-07 w/S2-08)*

Issued July 29, 2009:

1. Page 213, section F4.4, 2<sup>nd</sup> Paragraph: change “Figure F3-1” to “Figure F3-2.”

- Corrected sentence:
  - Jack rafters shall be connected to a hip member with a minimum 2 inch x 2 inch (51x51 mm) clip angle fastened with No. 10 screws to the hip member in accordance with Figure F3-2 and Table F3-3.