

- 1. Furring members shall meet ASTM C645 Standard Specification for Nonstructural Steel Framing Members.
- 2. Installation of furring members shall be in accordance with ASTM C754 Standard Specification for Installation Steel Framing Members to Receive Screw-Attached Gypsum Panel Products.
- 3. Gypsum panel type and thickness to meet specific application requirements.

DISCLAIMER: This detail must not be used without a complete evaluation by the owner's design professional to verify validity of the design.